



འཛིགས་མེད་དབང་ལྷན་ཁྲིམས་མེ་སྐོར་བཅའ་ཁྲིམས་ལང་།  
ལས་མི་འཆར་ཞི་དང་རིག་ཚལ་སྐོར་འཕེལ་ལས་ཁུངས་།

Jigme Wangchuck Power Training Institute  
Department of Workforce Planning and  
Skills Development  
Ministry of Education and Skills  
Development  
Dekiling: Sarpang



JWPTI/QAP.5.1/2025-26/586

Date: 07/03/2026

Subject: **Corrigendum No. 1**

Tender reference: **Design, Supply and Installation of 150 kW Rooftop Hybrid Solar PV System for Education and Training at Jigme Wangchuck Power Training Institute, Dekiling, Sarpang**


Dear Bidder(s),

This additional point (Sl.No.5) in the corrigendum No.1 shall form a part of the bidding document and shall be binding.

Sl. No	Clause No	Original Content	Revised Contend
1	ITB 12.1(j), Sl.no 11	The Bidder shall submit with its Bid the following additional documents: <b>-Test reports of the key components of the system</b>	The Bidder shall submit with its Bid the following additional documents: <b>-Test reports of the key components of the system can be submitted later only by successful bidder.</b>
2	ITB 12.1 (j), Sl.no 3	The Bidder shall submit with its Bid the following additional documents: <b>-Unique serial number and Model Number for the Solar modules, Inverters and BoS.</b>	The Bidder shall submit with its Bid the following additional documents: <b>Model Number for the Solar modules, Inverters and BoS.</b> -
3	Technical Specification, under Sl.no 6 (Instruction to Bidder), sub-point 9	Warranties shall include a minimum <b>one</b> (2) year defect liability period covering manufacturing, design, and installation defects from the date of system handover. The main	Warranties shall include a minimum <b>Two</b> (2) year defect liability period covering manufacturing, design, and installation defects from the date

		components, such as modules and inverters, shall carry warranties as specified in the technical requirements	of system handover. The main components, such as modules and inverters, shall carry warranties as specified in the technical requirements
4	Technical Specification, Sl. No 2 (site Location)	Site 1(Plumbing and Solar Technology Building) – Hybrid-grid PV generator of 150 KWp. With AC inverter <b>30KVA</b>  OR Site 2(Academic Building) – Hybrid-grid PV generator of 150 KWp. With AC inverter <b>30KVA</b>	Site 1(Plumbing and Solar Technology Building) – Hybrid-grid PV generator of 150 KWp. With AC inverter <b>50KVA</b>  OR Site 2(Academic Building) – Hybrid-grid PV generator of 150 KWp. With AC inverter <b>50KVA</b>
5	Section-II (Bid Data Sheet) ITB 3.1	Category of trade License eligible for this bidding process is: <b>Large Category Contractor registered with the Construction Development Board (CDB)</b> under Electrical installation and related services	Category of trade License eligible for this bidding process is [ <b>Category of trade license as per MoIC trade license Category</b> ]

Yours Sincerely,



Karma Dorji  
(Training Director)